



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA192946

**Certificate Holder:** Pink River Pty Ltd  
675 Macarthur Ave Central  
Pinkenba QLD 4008  
Australia

**Class Description:** Non-Prescribed  
**Product Description:** Surge Protection Device  
**Trade Name:** OBO BETTERMANN  
**Model No.:** V20-3+NPE+FS-280  
**Markings:** Uc L-N: 280V AC, (50/60Hz)  
N-PE: 255V AC; In L-N: 20kA,  
N-PE: 40kA; I<sub>max</sub> L-N: 40kA,  
N-PE: 60kA; Up L-N: ≤1.3kV,  
N-PE: ≤1.3kV;  
T2  
**Standard:** IEC 61643-11 Ed. 1.0  
**Conditions:** Nil

**Certification Mark:** RCM and SAA192946

**Date First Registered:** 28 November 2019  
**Date of Expiry:** 28 November 2024

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



Issued: 28-11-19 192946/1

[www.jas-anz.org/register](http://www.jas-anz.org/register)